

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2130093

Ordering firm: ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg, Germany

Manufacturer/Licence holder: ABB S.A.
Ruta 157- km 1233,5, 1661 Bella Vista, Argentina

Name of product: Miniature circuit breaker

Trade name:

Type of product: SH20.; SH20.L; SH20.T

Rating: AC 230/400 V
number of poles: 1, 2, 3, 4
characteristic: B 6-63 A; C 0,5-63 A; D 0,5-63 A
6 kA (SH20.), 4,5 kA (SH20.L), 3 kA (SH20.T)

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESC Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 303327-01/01 of: 29.11.2013

A sample of the product was tested and found to be in conformity with:
ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08;

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. ABB Automation 30021275 of 4.4.2013
- the Agreement on the use of the ESC Mark No. 303327 concluded between the ordering firm and the Electrotechnical Testing Institute

17.12.2013

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



303327-01